
A silhouette of a worker wearing a hard hat and safety harness is suspended on a cable against a bright, hazy sunset sky. The worker is positioned on the right side of the frame, looking towards the camera. The background shows a line of trees on a hillside under the warm light of the setting sun.


Ditch Requirements

UNDERGROUND DITCH REQUIREMENTS

Typical Primary



Typical Secondary



- DO NOT begin excavation of ditch until schedule has been coordinated with Laclede Electric personnel. Laclede Electric will not be responsible for collapsed or water filled ditches.
- Ditches are subject to inspection by Laclede Electric personnel. If a ditch fails to meet specifications the customer is responsible for all work necessary to correct.
- If rock is encountered reduced depths may be allowed in some cases with supplemental protection. Subject to approval by Laclede Electric personnel.